

# Electrical Installation Condition Report

Requirements for Electrical Installations - BS 7671:2018+A4:2026 as amended  
(IET Wiring Regulations 18th Edition)

## Guidance for recipients:

**This report is an important and valuable document which should be retained for future reference.**

1. The purpose of this Report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service at the date of inspection and testing (see Section E). The Report should identify any damage, deterioration, defects, dangerous conditions and/or non-compliances with the requirements of BS 7671, which might give rise to danger (see Section K).
2. This Report is only valid if accompanied by the Schedule(s) of Inspections and the Schedule(s) of Circuit Details and Schedule(s) of Test Results.
3. The person ordering the Report should have received the original Report and the inspector should have retained a duplicate.
4. The original Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner / occupier with details of the condition of the electrical installation at the time the Report was issued.
5. Section D (Extent and Limitations) should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.
6. Some operational limitations such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in Section D.
7. For items classified in Section K as C1 ("Danger Present"), **the safety of those using the installation is at risk**, and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work immediately.
8. For items classified in Section K as C2 ("Potentially Dangerous"), **the safety of those using the installation may be at risk** and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.
9. For items classified in Section K as C3 ('Improvement recommended'), in some cases, remedial work may improve the safety of the installation. However, it should be noted that a C3 recommendation is advisory only and does not affect the overall assessment of the Report.
10. Where further investigation is advised in Section K, this is because the inspection and testing has identified a potential issue for which the inspector is unable to determine a classification code until further investigation has taken place. In such cases it is recommended that further investigation is carried out to obtain the necessary information to allow the inspector to reach a conclusion for the appropriate classification code.
11. **For safety reasons**, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons competent in such work. The recommended date by which the next inspection is due is stated in Section F of the Report under 'Recommendations' and on a label at or near to the consumer unit /distribution board (where required).
12. Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. **For safety reasons it is important that this instruction is followed.**
13. Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions should be followed with respect to test button operation.
14. Where the installation includes a surge protective device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice. For safety reasons it is important that this instruction is followed.
15. Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

# ELECTRICAL INSTALLATION CONDITION REPORT

FT/EICR

648700003211

for Residential or Similar Premises up to 100 A

Requirements for Electrical Installations  
BS 7671:2018+A4:2026 as amended  
(IET Wiring Regulations 18th Edition)

## Section A: Details of the person ordering this Report

Details of the Client \_\_\_\_\_, Brighton,

## Section B: Reason for Producing this Report

Clients request.

Date(s) on which the inspection and testing were carried out 02/06/2026 to 02/06/2026

## Section C: Details of the Installation which is the Subject of this Report

Occupier Address \_\_\_\_\_, Brighton,

Description of premises Residential or Similar  Commercial / Industrial  Other (please specify) \_\_\_\_\_

Estimated age of the wiring system 15 years

Evidence of alterations or additions? Yes  No  Not apparent  if 'Yes', estimated \_\_\_\_\_ years

Installation records available? (Regulation 651.1) Yes  No  Date of last inspection Not Known

## Section D: Extent and Limitations of Inspection and Testing (see Regulation 651)

Details of those parts of the installation that have been inspected and tested

All fixed wiring. Not including heating controls.

Agreed limitations including the reason

ZS value is calculated by adding R1 + R2 readings to the ZDB. We do not test insulation resistance between live and neutral conductors in order to protect vulnerable electronic equipment. We will visually inspect the internal connections of 10% of each circuit (1 out of 10 sockets for example) unless we feel it necessary to investigate more.

Agreed with: Client

Unless specifically agreed between the client and inspector prior to the inspection:

- Cables concealed within trunking and conduits, under floors, in roof spaces, and generally within the fabric of the building or underground, have not been inspected.
- No checks for safety alerts, corrective actions or product recalls for electrical equipment forming part of the installation have been made.

An inspection should be made of other electrical equipment housed within an accessible roof space.

Operational limitations including the reason

The inspection and testing detailed within this report and accompanying schedules has been carried out in accordance with BS 7671:2018 amended to

2026

## Section E: Summary of the Condition of the Installation

Overall assessment of the installation as detailed in Section D SATISFACTORY  \*UNSATISFACTORY  in terms of suitability for continued service.

\*An unsatisfactory assessment indicates that dangerous (code C1) and/or potentially dangerous (code C2) conditions have been identified.

Where the overall assessment of the suitability of the installation for continued use above is stated as UNSATISFACTORY, any observations classified as 'Danger present' (code C1) or 'Potentially dangerous' (code C2) should be acted on as a matter of urgency.

General conditions of the installation (in terms of electrical safety)

Unfortunately we have discovered multiple code 2 observations which deem this installation as unsatisfactory. Please see observation list for further details.

Consumer unit contains two separate supplies, one being ON PEAK and the other OFF PEAK.

Any observation classified as 'Improvement recommended' (code C3), or 'Further investigation' (code FI), is advisory and does not affect the overall assessment but should be given due consideration.

## Section F: Recommendations for Next Inspection

Subject to the necessary remedial action being taken, I/We recommend that the installation is further inspected and tested before 02/06/2031 for the following reasons:

Please see observation list for full details.

## Section G: Declaration

I/we being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing hereby declare that the information in this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in section D of this report.

Company	Inspected and tested by	Authorised for issue by
Kingfisher Electrics Ltd	Name: Steven Fisher	Steven Fisher
Address: 275 Kingsway, HOVE, Hove,	Signature:	
Postcode: BN3 4LJ	Position: Electrician	Electrician
Branch No.: Hove	Date: 02/06/2026	02/06/2026
Scheme No.: 30283		

# ELECTRICAL INSTALLATION CONDITION REPORT

FT/EICR

6487000003211

for Residential or Similar Premises up to 100 A

Requirements for Electrical Installations  
BS 7671:2018+A4:2026 as amended  
(IET Wiring Regulations 18th Edition)

## Section H: Schedules and Continuation Sheet(s)

1	Continuation sheet(s) for Section(s)	N/A
1	schedule(s) of inspection	
1	schedule(s) of Circuit Details and Schedule(s) of Test Results.	

The Schedule(s) and continuation sheet(s) listed are part of this document and this report is valid only when they are attached to it.

## Section I: Supply Characteristics and Earthing Arrangements

<b>Earthing Arrangements</b>	<b>Number &amp; Type of live conductors</b>	<b>Nature of Supply Parameters</b>	<b>Supply Protective Device</b>
TN-C <input type="checkbox"/>	AC <input checked="" type="checkbox"/> DC <input type="checkbox"/>	Nominal voltage, U/U <sub>0</sub> <sup>(1)</sup> 230 V	BS (EN) 88-2 HRC gG
TN-S <input checked="" type="checkbox"/>	1-phase, 2-wire <input checked="" type="checkbox"/> 2-wire <input type="checkbox"/>	Nominal frequency, f <sup>(1)</sup> 50 Hz	Type gG
TN-C-S (PME) <input type="checkbox"/>	2-phase, 3-wire <input type="checkbox"/> 3-wire <input type="checkbox"/>	Prospective fault current, I <sub>pf</sub> <sup>(2)</sup> 0.562 kA	Rated Current 60 A
TN-C-S (PNB) <input type="checkbox"/>	3-phase, 3-wire <input type="checkbox"/> Other <input type="checkbox"/>	External loop impedance, Z <sub>e</sub> <sup>(2)</sup> 0.39 Ω	Breaking Capacity 16 kA
TT <input type="checkbox"/>	3-phase, 4-wire <input type="checkbox"/>	(Note: (1) by enquiry (2) by enquiry or by measurement)	
IT <input type="checkbox"/>	Confirmation of supply polarity <input checked="" type="checkbox"/>		

Other source of supply  No. of Additional Supplies N/A

## Section J: Particulars of Installation Referred to in the Report

<b>Means of Earthing</b>	<b>Details of installation Earth Electrode (where applicable)</b>
Distributor's facility <input checked="" type="checkbox"/> Installation Earth Electrode <input type="checkbox"/>	Type (e.g. rod(s), tape etc) N/A
<b>Maximum Demand</b>	Location N/A
Maximum Demand (load) 15 Amps <input checked="" type="checkbox"/> KVA <input type="checkbox"/>	Electrode resistance/Impedance Ra

### Main Protective Conductors

Earthing Conductor	Material Copper	csa 16 mm <sup>2</sup>	Connection / Continuity Verified <input checked="" type="checkbox"/>	Ω
Main Protective Bonding Conductors	Material Copper	csa 10 mm <sup>2</sup>	Connection / Continuity Verified <input checked="" type="checkbox"/>	Ω
To Water installation pipes <input checked="" type="checkbox"/>	To Gas installation pipes <input checked="" type="checkbox"/>	To Oil installation pipes <input type="checkbox"/>	To structural steel <input type="checkbox"/>	To lightning protection system <input type="checkbox"/>
To other <input type="checkbox"/>				

### Main Switch (Isolation devices / Switch-fuse / Circuit-breaker / RCD etc.)

Location Entrance High Level	<b>If overcurrent protective device</b>	<b>If RCD main switch:</b>
BS(EN) 60947-3	Device Type N/A	RCD Type AC
No. of Poles 2	Device rating/setting N/A A	Rated residual operating current I <sub>Δn</sub> 30 mA
Current Rating 100 A	Breaking capacity N/A kA	Rated time delay N/A ms
Voltage rating 230 V	Attach protective device settings where applicable on separate continuation sheet(s)	Measured operating trip time 27 ms
		Breaking Capacity 6 kA

## Section K: Observations

Referring to the attached inspection schedule(s) and schedule(s) of circuit details and test results, and subject to the limitations specified at the Extent and limitations of inspection and testing Section D.

 No remedial work required  The following observations are made

Item No.	C1 and C2 Observations	Code
3	Consumer unit contains a Type AC RCD module, which is no longer recommended for general use. The device should be replaced with an equivalent Type A RCD to provide appropriate protection for modern electrical loads.	C2
4	Circuits 1 and 2 are not provided with RCD protection. Additional protection should be introduced by means of suitably rated RCBOs.	C2
5	Off-peak storage heaters have been disconnected following the installation of central heating; however, redundant cables have been left in an unsafe condition. The cables should be suitably terminated and enclosed to prevent danger.	C2
6	Circuit 7 has an insulation resistance reading of 0.06 MΩ, which is significantly below the minimum acceptable value. The cause of the low insulation resistance must be investigated and rectified.	C2
7	Circuit 5 (Kitchen Sockets) has a slightly elevated CPC end-to-end resistance reading. This should be investigated to confirm the integrity and continuity of the protective conductor.	C2
8	The electric shower exhibits signs of thermal damage to internal connections. The shower must be replaced and the associated circuit connections inspected and rectified as necessary.	C2
9	The consumer unit contains 2 x plastic blanking plates that can be removed without the use of a tool, resulting in accessible openings within the enclosure. The blanking plates should be replaced with suitably secure blanks requiring the use of a tool for removal.	C2
10	Main protective bonding is only present at the water pipe serving the boiler. The gas pipework is not bonded and the main protective bonding arrangement should be reconfigured to ensure both services are correctly bonded in accordance with current requirements.	C2

One of the following codes, as appropriate, has been allocated to each of the observations made above to indicate to the person(s) responsible for the installation the advisory nature and degree of urgency for remedial action. These items do not affect the overall assessment of the report.

- C1 Danger present. Risk of Injury. Immediate remedial action required.
- C2 Potentially dangerous. Urgent remedial action required.

# ELECTRICAL INSTALLATION CONDITION REPORT

FT/EICR

6487000003211

for Residential or Similar Premises up to 100 A

Requirements for Electrical Installations

BS 7671:2018+A4:2026 as amended

(IET Wiring Regulations 18th Edition)

Item No.	C3 and FI Observations	Code
1	No surge protective device in place to protect vulnerable electronic equipment which may be plugged into sockets.	C3
2	Consumer unit is not fire rated.	C3

One of the following codes, as appropriate, has been allocated to each of the observations made above to indicate to the person(s) responsible for the installation the advisory nature degree of urgency for remedial action. These items do not affect the overall assessment of the report.

C3	Improvement recommended.
FI	Further investigation is advised

for Residential or Similar Premises up to 100 A

Requirements for Electrical Installation - BS 7671:2018+A4:2026 as amended (IET Wiring Regulations 18th Edition)

Outcomes							
Acceptable condition:	Unacceptable condition: State	Improvement recommended:	Further Investigation:	Not Verified:	Limitation:	Not Applicable:	Inadequacies: (Items 1.1 - 1.1.5 Only)
	or						
Item No.	Description						Outcome
<b>1.0 INTAKE EQUIPMENT (VISUAL INSPECTION ONLY)</b>							
<b>1.1</b>	<b>Distribution/supplier Intake equipment</b>						
1.1.1	- Service Cable						
1.1.2	- Service Head						
1.1.3	- Earthing Arrangement						
1.1.4	- Meter Tails						
1.1.5	- Metering Equipment						
1.1.6	- Means of Isolation (where present)						
1.2	Consumers Means of Isolation (where present)						
1.3	Consumers Meter Tails						
<b>2.0 PRESENCE OF ADEQUATE ARRANGEMENTS FOR OTHER SOURCES SUCH AS MICROGENERATORS (551.6; 551.7)</b>							
2.0	Presence of Adequate Arrangements for Other Sources such as Microgenerators						
<b>3.0 EARTHING / BONDING ARRANGEMENTS (411.3; Chap 54)</b>							
3.1	Presence and condition of distributors earthing arrangement (542.1.2.1; 542.1.2.2)						
3.2	Presence and condition of earth electrode connection where applicable (542.1.2.3)						
3.3	Provision of earthing/bonding labels at all appropriate locations (514.13.1)						
3.4	Confirmation of earthing conductor size (542.3; 543.1.1)						
3.5	Accessibility and condition of earthing conductor at MET (543.3.2)						
3.6	Confirmation of main protective bonding conductor sizes (544.1)						
3.7	Condition and accessibility of main protective bonding conductor connections (543.3.2; 544.1.2)						
3.8	Accessibility and condition of other protective bonding connections (543.3.1; 543.3.2)						
<b>4.0 CONSUMER UNIT(S) / DISTRIBUTION BOARD(S)</b>							
4.1	Adequacy of working space/accessibility to consumer unit/distribution board (132.12; 513.1)						
4.2	Security of fixing (134.1.1)						
4.3	Condition of enclosure(s) in terms of IP rating etc (416.2)						
4.4	Condition of enclosure(s) in terms of fire rating etc (421.1.201; 526.5)						
4.5	Enclosure not damaged/deteriorated so as to impair safety (651.2)						
4.6	Presence of main linked switch (as required by 462.1.201)						
4.7	Operation of main switch (functional check) (643.10)						
4.8	Manual operation of circuit-breaker and RCDs to prove disconnection (643.10)						
4.9	Correct identification of circuit details and protective devices (514.8.1; 514.9.1)						
4.10	Presence of RCD six-monthly test notice, where required (514.12.2)						
4.11	Presence of alternative supply warning notice at or near consumer unit/distribution board (514.15)						
4.12	Presence of other required labelling (please specify) (Section 514)						
4.13	Compatibility of protective devices, bases and other components; correct type and ratings (No signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.5; 411.6; Sections 432, 433)						
4.14	Single-pole switching or protective devices in line conductor only (132.14.1; 530.3.3)						
4.15	Protection against mechanical damage where cables enter consumer unit/distribution board (522.8.1; 522.8.5; 522.8.11)						
4.16	Protection against electromagnetic effects where cables enter consumer unit/distribution board/enclosures (521.5.1)						
4.17	RCDs provided for fault protection - includes RCBOs (411.4.204; 411.5.2; 531.2)						
4.18	RCDs provided for additional protection/requirements - includes RCBOs (411.3.3; 415.1)						
4.19	Confirmation of indication that SPD is functional (651.4)						
4.20	Confirmation that all conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)						
4.21	Adequate arrangements where a generating set operated as a switched alternative to the public supply (551.6)						
4.22	Adequate arrangements where a generating set operates in parallel with a public supply (551.7)						
4.23	Confirmation of indication that AFDD(s) are operational (421.1.7; 532.6; 651.2(e))						
<b>5.0 DISTRIBUTION / FINAL CIRCUITS</b>							
5.1	Identification of conductors (514.3.1)						
5.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)						
5.3	condition of insulation of live parts (416.1)						
5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1) * To include the integrity of conduit and trunking systems (metallic and plastic)						
5.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)						
5.6	Coordination between conductors and overload protective devices (433.1; 533.2.1)						
5.7	Adequacy of protective devices: type and rated current for fault protection (411.3; 530.3.201)						

for Residential or Similar Premises up to 100 A

Requirements for Electrical Installation - BS 7671:2018+A4:2026 as amended (IET Wiring Regulations 18th Edition)

5.8	Presence and adequacy of circuit protective conductors (411.3.1; Section 543)	
5.9	Wiring system(s) appropriate for the types and nature of the installation and external influences (Section 522)	
5.10	Concealed cables installed in prescribed zones (see Section D. Extent of limitations) (522.6.202)	
5.11	Cables concealed under floors, above ceilings or in walls/partitions, adequately protected against damage (see Section D. Extent of limitation) (522.6.204)	
<b>5.12</b>	<b>Provision of additional requirements for protection by RCD not exceeding 30 mA</b>	
5.12.1	- for all socket-outlets of rating not exceeding 32 A, unless an exception is permitted (411.3.3)	
5.12.2	- for the supply of mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)	
5.12.3	- for cables concealed in walls at a depth of less than 50 mm (522.6.202; Table 52.1)	
5.12.4	- for cables concealed in walls/partitions containing metal parts regardless of depth (Table 52.1)	
5.12.5	- Final circuits supplying luminaires within domestic (household) premises (411.3.4)	
5.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	
5.14	Band II cables segregated/separated from Band I cables (528.1)	
5.15	Cables segregated/separated from communications cabling (528.2)	
5.16	Cables segregated/separated from non-electrical services (528.3)	
5.17	Termination of cables at enclosures - indicate extent and location of sampling in Section D of the report (Section 526)	
5.17.1	Connections soundly made and under no undue strain (526.6)	
5.17.2	No basic insulation of a conductor visible outside enclosure (526.8)	
5.17.3	Connections of live conductors adequately enclosed (526.5)	
5.17.4	Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5)	
5.18	Condition of accessories including socket-outlets, switches and joint boxes (651.2(e))	
5.19	Suitability of accessories for external influences (512.2)	
5.20	Adequacy of working space/accessibility to equipment (132.12; 513.1)	
5.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	
<b>6.0 LOCATION(S) CONTAINING A BATH OR SHOWER</b>		
6.1	Additional protection for all low voltage (LV) circuits by RCD not exceeding 30 mA (701.411.3.3)	
6.2	Where used as a protective measure, requirements for SELV or PELV (701.414.4.5)	
6.3	Shaver supply units comply with BS EN 61558-2-5 formerly BS 3535 (701.512.3)	
6.4	Presence of supplementary bonding conductors, where required (701.415.2)	
6.5	Low voltage (e.g. 230 V) socket-outlets sited at least 2.5 m from zone 1 (701.512.3)	
6.6	Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2)	
6.7	Suitability of accessories and controlgear etc. for a particular zone (701.512.3)	
6.8	Suitability of current-using equipment for particular position within the location (701.55)	
<b>7.0 OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS</b>		
7.1	List all other special installations or locations present. (Record separately the results of particular inspections carried out and attach the report)	
<b>8.0 PROSUMERS LOW VOLTAGE ELECTRICAL INSTALLATION(S)</b>		
8.1	List all inspection items to Chapter 82. (Record separately the results of the particular inspections carried out and attach to the report)	

Inspector's Name:


Signature:

Date:





## Generic Continuation



# ELECTRICAL INSTALLATION CERTIFICATE

Requirements for Electrical Installations - BS 7671: 2018+A2:2022+A3:2024 as amended  
(IET Wiring Regulations 18th Edition)

## Guidance for recipients:

This safety Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with BS 7671 (the IET Wiring Regulations).

You should have received an 'original' Certificate and the person that issued the Certificate should have retained a duplicate.

If you were the person ordering this work, but not the owner of the installation, you should pass this Certificate, or a full copy of it, immediately to the owner. The original Certificate is to be retained in a safe place and be shown to any person inspecting or undertaking work on the electrical installation in the future.

If you later vacate the property, this Certificate will demonstrate to the new owner that the electrical installation complied with the requirements of BS 7671 at the time the Certificate was issued.

The Construction (Design and Management) Regulations require that, for a project covered by those Regulations, a copy of this certificate, together with schedules, is included in the project health and safety document.

For safety reasons, the electrical installation will need to be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The maximum time interval recommended before the next inspection is stated in Section 3 under "NEXT INSPECTION".

This Certificate is intended to be issued only for a new electrical installation or for new work associated with an addition or alteration to an existing installation. It should not have been issued for the inspection and testing of an existing electrical installation. An "Electrical Installation Condition Report" should be issued for such an inspection.

This Certificate is only valid if the Schedule of Inspections has been completed to confirm that all relevant inspections have been carried out and where accompanied by Schedule(s) of Circuit Details and Test Results.

Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions shall be followed with respect to test button operation.

Where the installation includes a surge protective device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

# ELECTRICAL INSTALLATION CERTIFICATE

FT/EIC 648700003201

for Residential or Similar Premises up to 100 A

Requirements for Electrical Installations  
BS 7671:2018+A2:2022+A3:2024 as amended  
(IET Wiring Regulations 18th Edition)

## Client Details

Client	Installation
Address	Address
Hove	Hove
Postcode	Postcode

## Details of the Installation

Description of premises Residential or Similar  Commercial  Industrial  Date of original installation

Installation is New  Addition  Alteration  Records Available Yes  No  RCD Risk assessment attached

Description of the installation

We have upgraded the consumer units plus other code 2 observations found during our recent EICR. Full details to be found on the generic continuation sheet attached.

Extent of the installation covered by this certificate

Items listed on generic continuation sheet only.

Details of departures from BS 7671 (regulations 120.3, 133.1.3 and 133.5)

Details of permitted exception. (regulation 411.3.3) where applicable a suitable risk assessment(s) must be attached to this certificate

## Declaration for Design, Construction, Inspection and Testing (for sole person responsibility)

I being the person responsible for design, construction, inspection and the test of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which i have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to  except for the departures, if any, listed below. The extent of liability of the signatory or the signatories is limited to work described in Section 2 as subject of this certificate.

For the DESIGN / CONSTRUCTION / INSPECTION & TEST of the installation:

Company	<input type="text" value="Kingfisher Electrics Ltd"/>	Position	<input type="text" value="Electrician"/>		
Inspector Name	<input type="text" value="Steven Fisher"/>	Date	<input type="text" value="08/05/2026"/>		
Address	<input type="text" value="275 Kingsway&lt;br/&gt;HOVE&lt;br/&gt;Hove&lt;br/&gt;BN3 4LJ"/>	Scheme No.	<input type="text" value="30283"/>	Branch No.	<input type="text" value="Hove"/>
		Signature	<input type="text"/>		
Reviewed By	<input type="text" value="Steven Fisher"/>	Reviewed By	<input type="text"/>		
Reviewed By Date	<input type="text" value="08/05/2026"/>	Signature	<input type="text"/>		

Next inspection I the designer recommend that this installation is further inspected after an interval of not more than  years

# ELECTRICAL INSTALLATION CERTIFICATE

FT/EIC 648700003201

for Residential or Similar Premises up to 100 A

Requirements for Electrical Installations  
BS 7671:2018+A2:2022+A3:2024 as amended  
(IET Wiring Regulations 18th Edition)

## Supply Characteristics and Earthing Arrangements

Earthing Arrangements TN-S  TN-C-S  TT  Other  If Other please specify N/ANumber & Type of live conductors AC  DC  No. of phases 1 No. of wires 2

### Nature of Supply Parameters (Note: <sup>(1)</sup> by enquiry, <sup>(2)</sup> by enquiry or by measurement)

Nominal voltage, U/U<sub>0</sub> <sup>(1)</sup> 230 v Nominal frequency, f<sup>(1)</sup> 50 Hz Confirmation of polarity Prospective fault current, I<sub>pf</sub> <sup>(2)</sup> 0.865 kA External loop impedance, Z<sub>e</sub> <sup>(2)</sup> 0.18 Ω

Supply Protective Device BS (EN) 88-2 HRC gG Type gG Rated Current 60 A

No. of Additional Supplies N/A

## Particulars of Installation at the Origin

**Details of installation Earth Electrode** (where applicable) Type (e.g. rod(s), tape etc) N/A Distributors facility  Installation Earth Electrode   
Location N/A Electrode resistance to earth N/A Ω Maximum Demand (load) 15 Amps  KVA 

Main Protective Conductors	Material	csa	(✓) or Value	(✓) or Value
Earthing Conductor	Copper	16	mm <sup>2</sup> Continuity Verified <input checked="" type="checkbox"/>	Ω Connection Verified <input checked="" type="checkbox"/>
Protective Bonding Conductor	Copper	10	mm <sup>2</sup> Continuity Verified <input checked="" type="checkbox"/>	Ω Connection Verified <input checked="" type="checkbox"/>

Main Supply Conductor	Material	csa	(connection / continuity) (✓) or Value	(✓) or Value
	Copper	25	mm <sup>2</sup> Water installation <input checked="" type="checkbox"/>	Ω To structural steel N/A <input type="checkbox"/>
Main Switch Location	Entrance High Level		Gas installation pipes <input checked="" type="checkbox"/>	Ω To lightning protection N/A <input type="checkbox"/>
			Oil installation pipes N/A <input type="checkbox"/>	Ω Other N/A <input type="checkbox"/>

Fuse/device rating or setting Switch A Voltage rating 230 V BS(EN) 60947-3 No. of Poles 2 Current Rating 100 A  
If RCD main switch: Rated residual operating current I<sub>Δn</sub> N/A mA Rated time delay N/A ms Measured operating trip time N/A ms

### Comments on existing installation (in case of addition or alteration see section 644.1.2) use continuation sheet if needed

We have upgraded the consumer units plus other code 2 observations found during our recent EICR. Full details to be found on the generic continuation sheet attached.

(For additions or alterations) cables concealed within trunking and conduits, or cables or conduits concealed under floors, in roof spaces and generally within the fabric of the building or underground may not have been inspected.

## Schedule of Inspection - Outcomes

Indicates an inspection has been carried out and the result is satisfactory		✓	Indicates the inspection is not applicable to a particular item		N/A
1.0	Condition of consumer's intake equipment (visual inspection only)	✓	8.0	Circuits (Distribution and Final)	✓
2.0	Parallel or switched alternative sources of supply	N/A	9.0	Isolation and switching	✓
3.0	Protective measure: Automatic Disconnection of Supply (ADS)	✓	10.0	Current-using equipment (permanently connected)	✓
4.0	Basic Protection	✓	11.0	Identification and notices	✓
5.0	Protective measure other than ADS	✓	12.0	Location(s) containing a bath or shower	✓
6.0	Additional protection	✓	13.0	Other special installations or locations	✓
7.0	Distribution equipment	✓	14.0	Prosumer's low voltage electrical installation(s)	N/A

**SCHEDULES:** This certificate is only valid when (enter quantities of schedules attached) 1 schedules of circuit details and test results are attached

Inspector's Name: Steven Fisher

Signature

Date: 08/05/2026



**ELECTRICAL INSTALLATION CERTIFICATE - Schedule of Test Results**

FT/EIC 648700003201

for Residential or Similar Premises up to 100 A

Requirements for Electrical Installations  
BS 7671:2018+A2:2022+A3:2024 as amended (IET Wiring Regulations  
18th Edition)

<b>Client Name</b>		<b>Installation Address</b>	
<b>Client Address</b>	Hove	<b>Client Postcode</b>	
		<b>Installation Postcode</b>	

<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location	Entrance High Level	Associated RCD (if any):	BS (EN) <input type="checkbox"/>
Designation	DB 1	Z <sub>db</sub>	<input type="text"/> Ω Operating at I <sub>Δn</sub> <input type="text"/> ms
No. of ways	8 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pr</sub>	<input type="text"/> kA No. of poles <input type="text"/> Time delay (if applicable) <input type="text"/>
No. of phases	1 SPD: <input type="checkbox"/> Operational status confirmed <input type="checkbox"/> Not applicable		

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity#	Max. Measured Z <sub>s</sub> (Ω)	RCD testing		Manual test button operation	
	Ring final circuits only			Fig 6 check (✓)	R + R or R		Test voltage‡‡ V	L/L, L/N	L/E, N/E			All RCDs I <sub>Δn</sub> ms	RCD (✓)	AFDD (✓)	
	r <sub>1</sub>	r <sub>n</sub>	r <sub>2</sub>		R + R	R		M(Ω)	M(Ω)						
1/S	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
2/S	0.29	0.26	0.41	✓	0.35	N/A	500	15	15	✓	0.53	33	✓	N/A	
3/S	N/A	N/A	N/A	N/A	0.61	N/A	500	20	20	✓	0.80	33	✓	N/A	
4/S	N/A	N/A	N/A	N/A	0.34	N/A	500	20	20	✓	0.53	35	✓	N/A	
5/S	N/A	N/A	N/A	N/A	0.09	N/A	500	>200	>200	✓	0.27	39	✓	N/A	
6/S	N/A	N/A	N/A	N/A	N/A	2.3	500	20	20	✓	2.48	33	✓	N/A	
8/S	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
9/S	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

<b>Details of circuits and/or installed equipment vulnerable to damage when testing</b>		Date(s) dead testing	08/05/2026	To	08/05/2026					
		Date(s) live testing	08/05/2026	To	08/05/2026					
Test instrument serial number(s)	Loop impedance	11N-1588	Insulation resistance	11N-1588	Continuity	11N-1588	RCD	11N-1588	E/Electrode	
<b>Tested by: Name (capital letters)</b>		STEVEN FISHER				<b>Signature</b>				
<b>Position</b>		Electrician		<b>Date</b>		08/05/2026				

†† Not all SPDs have visible functionality indication. # An 'X', denoting incorrect polarity, cannot be entered on to this schedule when issued with an Electrical Installation Certificate.  
 ‡‡ RCD effectiveness is verified using an alternating current test at rated residual operating current (IDeltan). ‡‡ Where this schedule forms part of an Electrical Installation Certificate, insulation resistance testing should be performed at the test voltage stated in Table 64. ‡‡ Not all AFDDs have a test button.

## Generic Continuation

This installation certificate follows our recent EICR 648700003169 and includes the following remedial works which brings the installation up to a satisfactory standard;

### Essential Works:

1) Consumer unit contains Type AC RCD modules, non-compliant blanking plates, and poor cable entries. Additionally, mixed manufacturer components have been used. It is recommended that the consumer unit is replaced to ensure compliance and reliability.

\* Replacement of consumer unit with a fire rated version, offering both surge and RCD protection to the following circuits;

1 x B32,  
3 x B20's &  
1 x B6

Din rail blanks to fill (at least) 2 spare ways (if possible).

2) Socket outlet in the utility room is not securely fixed to the back box and must be re-secured.

3) Circuit 2 has elevated end-to-end continuity readings on the neutral conductor. Due to the size of the circuit, it is recommended that once the fault has been identified, the circuit is downgraded and split into smaller circuits.

4) Socket outlet located below the window on the left-hand side of the lounge is difficult to insert a plug into on one side and records a high R1+R2 value on the other. This must be replaced.

5) Socket outlets supplying the washing machine and tumble dryer could not be located at the time of inspection. This requires investigation, and if found to be in an inaccessible position, they must be relocated to an accessible location such as a nearby cupboard.

6) Issuing of EIC testing certification with clearly stated 'satisfactory' status.

### Extra Works:

1) Wall-mounted light fittings at the rear of the lounge are not functioning. The client has requested investigation and repair to restore operation.

2) Bathroom extract fan is not functioning. The client has requested replacement of the unit.

3) Small toilet extract fan is not functioning. The client has requested replacement of the unit.

4) Installation of customer-supplied induction hob.

Please note: this will require the circuit to be upgraded to a B32, as the hob is 6.9kW.

5) Replacement of 4 x downlights in kitchen.

6) Replacement of 6 x downlights in bathroom.

7) Remove 2 x downlights in mid bedroom and install them in rear bedroom. Then install new customer-supplied wall lights in mid bedroom.

# Minor Electrical Installation Works Certificate

Requirements for Electrical Installations  
BS 7671:2018+A2:2022+A3:2024 as amended (IET Wiring Regulations 18th Edition)

## Information for recipients:

This safety Certificate for Minor Works has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with BS 7671 (the IET Wiring Regulations).

You should have received an original Certificate and the contractor should have retained a duplicate.

If you were the person ordering this work, but not the owner of the installation, you should pass this Certificate, or a copy of it, immediately to the owner. Separate Certificate(s) should be received for each existing circuit on which the minor works have been carried out.

The Certificate is not appropriate if you have requested the contractor to undertake more extensive installation work, for which you should have received an Electrical Installation Certificate. The original Certificate is to be retained in a safe place and be shown to any person inspecting or undertaking work on the electrical installation in the future.

If you later vacate the property, this Certificate will demonstrate to the new owner that the minor electrical installation work carried out complied with the requirements of BS 7671 at the time the Certificate was issued.

For safety reasons the electrical installation will need to be re-inspected at appropriate intervals by a skilled person or persons, competent in such work.

Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. For safety reasons it is important that this instruction is followed.

# Minor Electrical Installation Works Certificate

FT/MWM

6487000003160

Requirements for Electrical Installations BS 7671:2018+A2:2022  
+A3:2024 as amended (IET Wiring Regulations 18th Edition)

To be used only for minor electrical work which does not include the provision of a new circuit

## PART 1: Description of the Minor Works

1) Details of the Client	<input type="text"/>	Date minor works completed	<input type="text" value="24/03/2026"/>
2) Installation Location / Address	<input type="text"/>		
Installation	<input type="text"/>		
Address	<input type="text" value="Brighton"/>		
Postcode	<input type="text"/>		
3) Description of minor works	<input type="text" value="Installation of double socket below consumer unit."/>		
4) Details of departures if any from BS 7671:2018+A2:2022 for the circuit altered or extended (Regulation 120.3, 133.1.3, 133.5)	<input type="text"/>		
Details of permitted exceptions (Regulation 411.3.3) Where applicable, a risk assessment(s) must be attached to the Certificate	<input type="text" value="N/A"/>		
<input type="checkbox"/> Risk Assessment attached			
5) Comments on (including any defects observed in) the existing installation (Regulation 644.1.2):	<input type="text" value="N/A"/>		

## PART 2: Presence and adequacy of installation earthing and bonding arrangements (Regulation 132.16)

1) System earthing arrangement	TN-S <input type="checkbox"/>	TN-C-S <input checked="" type="checkbox"/>	TT <input type="checkbox"/>	2) Earth fault loop impedance at distribution board ( $Z_{db}$ ) supplying the final circuit	<input type="text" value="0.27"/>	$\Omega$
3) Presence of adequate main protective conductors	Earthing conductor	<input checked="" type="checkbox"/>				
Main protective bonding conductor(s) to	Water	<input checked="" type="checkbox"/>	Gas	<input checked="" type="checkbox"/>	Oil	<input type="text" value="NA"/>
	Structural steel	<input type="text" value="NA"/>	Other (Specify)	<input type="text" value="NA"/>		

## PART 3: Circuit details

Installation Reference Method	<input type="text" value="100"/>						
DB Reference No.	<input type="text" value="1"/>	DB location and type	<input type="text" value="Hall Cupboard"/>				
Circuit No.	<input type="text" value="11"/>	Circuit description	<input type="text" value="Socket: DB"/>				
Conductor sizes:	Live	<input type="text" value="2.5"/>	mm <sup>2</sup>	cpc	<input type="text" value="1.5"/>	mm <sup>2</sup>	
Circuit overcurrent protective device	BS (EN)	<input type="text" value="60898"/>	Type	<input type="text" value="B"/>	Rating	<input type="text" value="16"/>	A
RCD	BS (EN)	<input type="text" value="61008"/>	Type	<input type="text" value="AC"/>	Rating	<input type="text" value="63"/>	A
					Rated Residual Operating Current $I_{\Delta n}$	<input type="text" value="30"/>	mA
AFDD	BS (EN)	<input type="text" value="N/A"/>	Type	<input type="text" value="N/A"/>	SPD	BS (EN)	<input type="text" value="N/A"/>
					Type	<input type="text" value="N/A"/>	

## PART 4: Test results for the circuit altered or extended (were relevant and practicable)

Protective conductor continuity	Continuity of ring final circuit conductors	Insulation resistance	RCD disconnection time at rated residual operating current ( $I_{\Delta n}$ )	<input type="text" value="21"/>	ms		
$R_1 + R_2$	L/L	Live-Live	<input type="text" value="&gt;200"/>	M $\Omega$			
<input type="text" value="0.01"/>	<input type="text" value="N/A"/>	Live-Earth	<input type="text" value="&gt;200"/>	M $\Omega$			
or $R_2$	N/N	Test Voltage	<input type="text" value="500"/>	V			
<input type="text" value="N/A"/>	cpc/cpc						
	<input type="text" value="N/A"/>						
AFDD satisfactory test button operation	<input type="text" value="NA"/>	SPD Functionality Confirmed	<input type="text" value="NA"/>	<input checked="" type="checkbox"/> Polarity satisfactory	Maximum Measured Earth fault loop impedance $Z_s$	<input type="text" value="0.31"/>	$\Omega$
Test instruments (serial numbers) used:							
Earth fault loop impedance	<input type="text" value="11N-1588"/>	RCD	<input type="text" value="11N-1588"/>	Continuity	<input type="text" value="11N-1588"/>		
Insulation resistance	<input type="text" value="11N-1588"/>	Multi-function	<input type="text" value=""/>	Other	<input type="text" value=""/>		

## PART 5: Declaration

I certify that the work covered by the certificate does not impair the safety of the existing installation and the work has been designed, constructed, inspected and tested in accordance with BS 7671:2018+A2:2022 (IET Wiring Regulations) amended to 2024 and that to the best of my knowledge and belief at the time of my inspection complied with BS 7671 except as detailed in PART 1 above.

Company	<input type="text" value="Kingfisher Electrics Ltd"/>	Signature	<input type="text"/>
Inspector Name	<input type="text" value="Steven Fisher"/>	Position	<input type="text" value="Electrician"/>
Address	<input type="text" value="275 Kingsway, HOVE, Hove, BN3 4LJ"/>	Date	<input type="text" value="24/03/2026"/>
		Scheme No.	<input type="text" value="30283"/>
		Branch No.	<input type="text" value="Hove"/>
Reviewed by the Qualified Supervisor		Reviewed By	<input type="text"/>
Reviewed By	<input type="text" value="Steven Fisher"/>	Reviewed By Date	<input type="text" value="24/03/2026"/>
Reviewed By Date	<input type="text" value="24/03/2026"/>	Reviewed By Signature	<input type="text"/>

# Portable /Fixed Appliance

FT/PAT 6487000003174

Equipment formal visual and combined inspection and test

## Part 1: Details of Installation

Client	C/O	Installation	C/O	Inspector Name	Steven Fisher		
Address	Brighton	Address	Worthing	Branch No.	Hove	Scheme No.	30283
Postcode		Postcode		Date of Test	08/04/2026	Date of Re-test	08/04/2027
				Test Equipment	11N-1588		
				Signature			

## Part 2: Test Results

Appliance No.	Description	Date of test	Serial / Identification No.	Class I / II	Fuse size	Visual Only	Continuity/ Earth Bond $\Omega$	Polarity	Insulation M $\Omega$	Load KW	Function Run	Earth leak mA	RCD Check	Repair Code	Pass / Fail	Location
1	Washing Machine	08/04/2026	562408004583	I	13	✓	0.03	✓	>200	1.8	✓	N/A	✓	N/A	✓	Kitchen
2	Tumble dryer	08/04/2026	23572054	I	13	✓	0.33	✓	>200	2.35	✓	N/A	✓	N/A	✓	Kitchen
3	Toaster	08/04/2026	22008166	I	10	✓	0.27	✓	>200	0.8	✓	N/A	✓	N/A	✓	Kitchen
4	Kettle	08/04/2026	00822FD	I	13	✓	0.14	✓	>200	2.5	✓	N/A	✓	N/A	✓	Kitchen
5	Microwave	08/04/2026	20241100171	I	13	✓	0.40	✓	>200	1.28	✓	N/A	✓	N/A	✓	Kitchen
6	Fridge freezer	08/04/2026	22-101113-04	I	13	✓	0.16	✓	>200	0.18	✓	N/A	✓	N/A	✓	Kitchen

Repair codes: 1 - Damaged flex – Re-terminated 2 - Damaged – Plug removed 3 - Safety fault R1 - Replaced plug top R2 - Replaced plug top fuse R3 - Change plug top fuse from 13A to 3A fuse R4 - Change plug top fuse from 13A to 5A fuse R5 - Change plug top fuse from 13A to 10A fuse R6 - Replaced extension lead R7 - Shortened damaged power-cord/cable and refitted plug top R8 - Rewired incorrectly wired plug top R9 - Repaired/refitted insecure or wrongly fitted power-cord/cable grip R10 - Removed cardboard wiring diagram from plug top (Fire hazard) R11 - Repaired or refitted appliance case

# Portable /Fixed Appliance

FT/PAT 6487000003174

Equipment formal visual and combined inspection and test

## Test Result Totals & Notes:

Total Items Tested:

Total Failed Items Tested:

Appliance No. 2 Notes - This appliance is hard-wired

Repair codes: 1 - Damaged flex – Re-terminated 2 - Damaged – Plug removed 3 - Safety fault R1 - Replaced plug top R2 - Replaced plug top fuse R3 - Change plug top fuse from 13A to 3A fuse R4 - Change plug top fuse from 13A to 5A fuse R5 - Change plug top fuse from 13A to 10A fuse R6 - Replaced extension lead R7 - Shortened damaged power-cord/cable and refitted plug top R8 - Rewired incorrectly wired plug top R9 - Repaired/refitted insecure or wrongly fitted power-cord/cable grip R10 - Removed cardboard wiring diagram from plug top (Fire hazard) R11 - Repaired or refitted appliance case